



DEFENSE SYSTEMS RESEARCH INSTITUTE

Accredited by ISO / IEC 17025 : 2017 (NABL)

Lab Location : DSRI Labs Private Limited, Plot No 21, Road Number 4, IE, Nacharam, Road,
IDA Mallapur, Hyderabad - 500 076, Telangana, Website : <https://dsri.co.in> Email : info@dsri.co.in



TEST REPORT

01	Test Report No:	DSRI/ETL/1397/24
02	Date of Receipt:	22 nd July 2024
03	Nomenclature of item tested:	25NB PN10 Screw Down Non-Return Straight Valve (WCB)
		Valve Sl. No : CI0970
04	Serial No.:	Drawing No. : RV/SDNR/FLG/001
		Body Heat No : 92-06
05	Quantity:	01 Unit
		M/s. Rappid Valves, Genesis Industrial Complex, Plot 30 & 31 Village Kolgaon, Palghar east, District-palghar, Maharashtra 401404, India.
06	Testing requested by:	
07	Manufactured by:	M/s. Rappid Valves (India) Pvt. Ltd. District-Palghar, Maharashtra.
08	Test Name:	Flow Coefficient Test & Pressure Drop Test
09	Test Standard:	ANSI/ISA-A75.01
10	Test starting date:	18 th July 2024
11	Test completion date:	18 th July 2024
12	Date of Issue:	22 nd July 2024

Authorized By

A. Prasant Gopal

Managing Director, DSRI



DSRI/F/64 Issue no: 02, Issue Date: 22-07-2024 Rev. no: 00, Rev Date: --	URL No: TC120602400001397F
Test Report No: DSRI/ETL/1397/24	Prepared by:

Test results refer to the documented test samples only. Test report shall not be reproduced except in full, without written approval of the laboratory. Sample has been provided by the customer and the results apply to the sample as received. Sample description in all cases in taken as described by the customer.



TEST REPORT

- 13 **Test Request Control No& Date:** 1397/24, 22nd Jul 2024
- 14 **Test Specification** As per the standard
- 15 **UUT Condition:** Good
- 16 **Unique ID No. of Test Item:** DSRI/ETL/24/459/01
- 17 **Environmental Conditions:** Temp: 36.8°C, Humidity: 54.8%RH
- 18 **Test carried out at:** ET LAB
- 19 **Deviation if any:** No Deviation
- 20 **Equipment Used for test**
 - Nomenclature:** Ultrasonic Flow meter
 - Make/Model:** ADEPT/UFM 6720
 - Calibration Validity:** 24th February 2025
 - Pressure Gauges used**
 - Pressure gauge -I : 053533692493
 - Pressure gauge –II : 053860344134
 - Pressure gauge range: 0 to 2 Bar
 - Calibration Validity : 13th Jun 2025
- 21 **Test Setup:** Flow coefficient test setup is carried out as shown in the fig
- 22 **Test Procedure:** Set up the pressure gauges and flow meter in their designated locations according to the test specifications. Position the valve in the fully open state and measure both the flow rate and the pressure drop (Δp) across the valve. Record the inlet water temperature. Adjust the valve to various openings and measure the flow rate and pressure drop (Δp) for each setting. Perform each measurement at least three times to ensure accuracy and consistency.

DSRI/F/64 Issue no: 02, Issue Date: 22-07-2024 Rev. no: 00, Rev Date: --	URL No: TC120602400001397F
Test Report No: DSRI/ETL/1397/24	Prepared by:

Test results refer to the documented test samples only. Test report shall not be reproduced except in full, without written approval of the laboratory. Sample has been provided by the customer and the results apply to the sample as received. Sample description in all cases in taken as described by the customer.



TEST REPORT

23 Observation:

No structural deformity or damage was found during and after the test.

24 Conclusion:

Flow coefficient test for the unit '25NB PN10 Screw Down Non-Return Straight Valve Sl. No: CI0970 and Quantity: 01' is completed as per test specification conforming to the test method and standard of this report and unit condition is good as before the test

Test Figure:



DSRI/F/64 Issue no: 02, Issue Date: 22-07-2024 Rev. no: 00, Rev Date: --	URL No: TC120602400001397F
Test Report No: DSRI/ETL/1397/24	Prepared by:

Test results refer to the documented test samples only. Test report shall not be reproduced except in full, without written approval of the laboratory. Sample has been provided by the customer and the results apply to the sample as received. Sample description in all cases in taken as described by the customer.



DEFENSE SYSTEMS RESEARCH INSTITUTE

Accredited by ISO / IEC 17025 : 2017 (NABL)

Lab Location : DSRI Labs Private Limited, Plot No 21, Road Number 4, IE, Nacharam, Road,
IDA Mallapur, Hyderabad - 500 076, Telangana, Website : <https://dsri.co.in> Email : info@dsri.co.in



TEST REPORT

Test Results

Opeing Deg	T in Degree	ρ_1 (kg/m ³)	(ρ_1/ρ_0)	ΔP (PSI)	Q (GPM)	N1	cv	mean CV
90.00	29.5	996.1	0.9961	2	54	1	38.11	21.33
90.00	29.5	996.1	0.9961	4	34	1	16.97	
90.00	29.5	996.1	0.9961	5	20	1	8.93	
80.00	29.5	996.2	0.9962	2	45	1	31.76	17.96
80.00	29.5	996.2	0.9962	4	30	1	14.97	
80.00	29.5	996.2	0.9962	5	16	1	7.14	
70.00	29.7	996.3	0.9963	2	40	1	28.23	16.15
70.00	29.7	996.3	0.9963	4	28	1	13.97	
70.00	29.7	996.3	0.9963	5	14	1	6.25	
60.00	29.7	996.1	0.9961	2	34	1	23.99	14.25
60.00	29.7	996.1	0.9961	4	23	1	13.25	
60.00	29.7	996.1	0.9961	5	11	1	5.49	
50.00	29.6	996.1	0.9961	2	28	1	19.76	11.57
50.00	29.6	996.1	0.9961	4	19	1	10.95	
50.00	29.6	996.1	0.9961	5	8	1	3.99	
40.00	29.6	996.2	0.9962	2	21	1	14.82	8.44
40.00	29.6	996.2	0.9962	4	13	1	7.49	
40.00	29.6	996.2	0.9962	5	6	1	2.99	
20.00	29.8	997.1	0.9971	2	16	1	11.30	5.99
20.00	29.8	997.1	0.9971	4	9	1	5.19	
20.00	29.8	997.1	0.9971	5	3	1	1.50	

****END OF REPORT****

DSRI/F/64 Issue no: 02, Issue Date: 22-07-2024 Rev. no: 00, Rev Date: --	URL No: TC120602400001397F
Test Report No: DSRI/ETL/1397/24	Prepared by:

Test results refer to the documented test samples only. Test report shall not be reproduced except in full, without written approval of the laboratory. Sample has been provided by the customer and the results apply to the sample as received. Sample description in all cases in taken as described by the customer.



TEST REPORT

01	Test Report No:	DSRI/ETL/1399/24
02	Date of Receipt:	22 nd July 2024
03	Nomenclature of item tested:	25NB PN10 Screw Down Non-Return Straight Valve (WCB) Valve Sl. No : CI0970
04	Serial No:	Drawing No. : RV/SDNR/FLG/001 Body Heat No : 92-06
05	Quantity:	01
06	Testing requested by:	M/s. Rappid Valves, Genesis Industrial Complex, Plot 30 & 31 Village Kolgaon, Palghar east, District-palghar, Maharashtra 401404, India.
07	Manufactured by:	M/s. Rappid Valves (India) Pvt. Ltd. District-Palghar, Maharashtra.
08	Test Name:	Shock test
09	Test Standard:	NSS II
10	Test starting date:	18 th July 2024
11	Test completion date:	18 th July 2024
12	Date of Issue:	22 nd July 2024

Authorized By

A. Prasant Gopal
Managing Director, DSRI



DSRI/F/64 Issue no: 02, Issue Date: 22-07-2024 Rev. no: 00, Rev Date: --	URL No: TC120602400001399F
Test Report No: DSRI/ETL/1399/24	Prepared by:

Test results refer to the documented test samples only. Test report shall not be reproduced except in full, without written approval of the laboratory. Sample has been provided by the customer and the results apply to the sample as received. Sample description in all cases in taken as described by the customer.



TEST REPORT

- 13 Test Request Control No& Date:** 1399/24, 22nd July 2024
- 14 Test Specification** Acceleration : 276g
Pule Duration : 3.4msec,
One shock per direction.
- 15 UUT Condition:** Good
- 16 Unique ID No. of Test Item:** DSRI/ETL/24/459/01
- 17 Environmental Conditions:** Temp: 34.8°C, Humidity: 50.5%RH
- 18 Test carried out at:** ET LAB
- 19 Deviation if any:** No Deviation
- 20 Equipment Used for test**
- 21 Nomenclature:** Shock Test Machine
Make/Model: NMSRI/TSTS-1010S
Calibration Validity: 10th September 2024
- 22 Test Setup:** The 25NB PN10 Screw Down Non-Return Straight Valve, SI. No: CI0970, manufactured by M/s Rappid Valves (India) Pvt. Ltd., been fixed to shock machine along with dedicated fixture in “As Fitted Condition”.
- 23 Test Procedure:** Unit Under Test and accelerometer was mounted on the fixture as shown in figure and test was carried out as per the test method and standard for the required test specification.
- 24 Observation:** No structural deformity or damage was found during and after the test.
- 25 Conclusion:** The condition of UUT was found to be satisfactory upon visual inspection.

DSRI/F/64 Issue no: 02, Issue Date: 22-07-2024 Rev. no: 00, Rev Date: --	URL No: TC120602400001399F
Test Report No: DSRI/ETL/1399/24	Prepared by:

Test results refer to the documented test samples only. Test report shall not be reproduced except in full, without written approval of the laboratory. Sample has been provided by the customer and the results apply to the sample as received. Sample description in all cases in taken as described by the customer.



TEST REPORT

Test Figure:



Figure-1: 25NB PN10 Screw Down Non-Return Straight Valve

DSRI/F/64 Issue no: 02, Issue Date: 22-07-2024 Rev. no: 00, Rev Date: --	URL No: TC120602400001399F
Test Report No: DSRI/ETL/1399/24	Prepared by:

Test results refer to the documented test samples only. Test report shall not be reproduced except in full, without written approval of the laboratory. Sample has been provided by the customer and the results apply to the sample as received. Sample description in all cases in taken as described by the customer.



TEST REPORT

Test Graphs:




Fig-2: 276g for 3.4msec

****END OF REPORT****

DSRI/F/64 Issue no: 02, Issue Date: 22-07-2024 Rev. no: 00, Rev Date: --	URL No: TC120602400001399F
Test Report No: DSRI/ETL/1399/24	Prepared by:

Test results refer to the documented test samples only. Test report shall not be reproduced except in full, without written approval of the laboratory. Sample has been provided by the customer and the results apply to the sample as received. Sample description in all cases in taken as described by the customer.



DEFENSE SYSTEMS RESEARCH INSTITUTE

Accredited by ISO / IEC 17025 : 2017 (NABL)

Lab Location : DSRI Labs Private Limited, Plot No 21, Road Number 4, IE, Nacharam, Road,
IDA Mallapur, Hyderabad - 500 076, Telangana, Website : <https://dsri.co.in> Email : info@dsri.co.in

JOINT INSPECTION REPORT FOR TORQUE TEST

Test conducted date: 19-07-2024

Report issued date: 19-07-2024

**Report NO.: DSRI/Rappid/Screw Down Non-Return Straight Valve/25NB/Torque
Test-4**

Sl No.	Contents	Description
01	Client:	M/s. Rappid Valves (India) Private Limited
02	P.O No:	
03	Test Item:	25NB/PN10 Screw Down Non-Return Straight Valve Flanged Ends
04	S. No & Heat No.:	CIO970; 92-06
05	Material:	WCB
06	Drawing No.:	RV/SDNR/FLG/001
07	Torque Wrench	
	Make/Model no.:	Griphold_GTW_50
	Range: Calib due date:	14-68 Nm; 06-10-2023 05-10-2024
08	Pressure Gauge used:	Pressure gauge (0-21bars)
09	Serial Number/ Id No.:	0-21bars_ Serial no: ECPL/M/P/11
		ID. No: NMSRI/WI-PG-070
10	Due Of Calibration:	Serial no: ECPL/M/P/11_09-09-2023
		ID. No: NMSRI/WI-PG-021_08-09-2024
11	Closing Torque:	24 N-m
12	Opening Torque:	26 N-m
13	Delay Torque Time:	2sec
14	Observation:	During the hydrostatic torque test at 10 bar pressure, the opening torque was measured at 24 Nm, the closing torque at 26 Nm, and the delay torque time is 2sec. These values indicate the valve's performance under pressure, ensuring its reliability and functionality in the system.

Test Engineer

B. Ravi Kumar
DSRI Labs Pvt. Ltd., (LAB)





DEFENSE SYSTEMS RESEARCH INSTITUTE

Accredited by ISO / IEC 17025 : 2017 (NABL)

Lab Location : DSRI Labs Private Limited, Plot No 21, Road Number 4, IE, Nacharam, Road,
IDA Mallapur, Hyderabad - 500 076, Telangana, Website : <https://dsri.co.in> Email : info@dsri.co.in

Test Figure:



Figure 1: 25NB PN10 TORQUE TEST SETUP



DEFENSE SYSTEMS RESEARCH INSTITUTE

Accredited by ISO / IEC 17025 : 2017 (NABL)

Lab Location : DSRI Labs Private Limited, Plot No 21, Road Number 4, IE, Nacharam, Road,
IDA Mallapur, Hyderabad - 500 076, Telangana, Website : <https://dsri.co.in> Email : info@dsri.co.in



TEST REPORT

01	Test Report No:	DSRI/ETL/1403/24
02	Date of Receipt:	22 nd July 2024
03	Nomenclature of item tested:	40NB PN10 Screw Down Non-Return Straight Valve (WCB)
		Valve Sl. No : CI0971
04	Serial No.:	Drawing No. : RV/SDNR/FLG/001
		Body Heat No : 92-06
05	Quantity:	01 Unit
		M/s. Rappid Valves, Genesis Industrial Complex, Plot 30 & 31 Village Kolgaon, Palghar east, District-palghar, Maharashtra 401404, India.
06	Testing requested by:	
07	Manufactured by:	M/s. Rappid Valves (India) Pvt. Ltd. District-Palghar, Maharashtra.
08	Test Name:	Flow Coefficient Test & Pressure Drop Test
09	Test Standard:	ANSI/ISA-A75.01
10	Test starting date:	18 th July 2024
11	Test completion date:	18 th July 2024
12	Date of Issue:	22 nd July 2024

Authorized By



A. Prasant Gopal

Managing Director, DSRI

DSRI/F/64 Issue no: 02, Issue Date: 22-07-2024 Rev. no: 00, Rev Date: --	URL No: TC120602400001403F
Test Report No: DSRI/ETL/1403/24	Prepared by:

Test results refer to the documented test samples only. Test report shall not be reproduced except in full, without written approval of the laboratory. Sample has been provided by the customer and the results apply to the sample as received. Sample description in all cases is taken as described by the customer.



TEST REPORT

- 13 **Test Request Control No& Date:** 1403/24, 22nd Jul 2024
- 14 **Test Specification** As per the standard
- 15 **UUT Condition:** Good
- 16 **Unique ID No. of Test Item:** DSRI/ETL/24/461/01
- 17 **Environmental Conditions:** Temp: 36.8°C, Humidity: 54.8%RH
- 18 **Test carried out at:** ET LAB
- 19 **Deviation if any:** No Deviation

Equipment Used for test

- 20 **Nomenclature:** Ultrasonic Flow meter
- Make/Model:** ADEPT/UFM 6720
- Calibration Validity:** 24th February 2025
- Pressure Gauges used**
 - Pressure gauge -I : 053533692493
 - Pressure gauge -II : 053860344134
 - Pressure gauge range: 0 to 2 Bar
 - Calibration Validity : 13th Jun 2025

21 **Test Setup:** Flow coefficient test setup is carried out as shown in the fig

22 **Test Procedure:** Set up the pressure gauges and flow meter in their designated locations according to the test specifications. Position the valve in the fully open state and measure both the flow rate and the pressure drop (Δp) across the valve. Record the inlet water temperature. Adjust the valve to various openings and measure the flow rate and pressure drop (Δp) for each setting. Perform each measurement at least three times to ensure accuracy and consistency.

DSRI/F/64 Issue no: 02, Issue Date: 22-07-2024 Rev. no: 00, Rev Date: --	URL No: TC120602400001403F
Test Report No: DSRI/ETL/1403/24	Prepared by:

Test results refer to the documented test samples only. Test report shall not be reproduced except in full, without written approval of the laboratory. Sample has been provided by the customer and the results apply to the sample as received. Sample description in all cases in taken as described by the customer.



TEST REPORT

23 Observation:

No structural deformity or damage was found during and after the test.

24 Conclusion:

Flow coefficient test for the unit '40NB PN10 Screw Down Non-Return Straight Valve Sl. No: CI0971 and Quantity: 01' is completed as per test specification conforming to the test method and standard of this report and unit condition is good as before the test

Test Figure:



DSRI/F/64 Issue no: 02, Issue Date: 22-07-2024 Rev. no: 00, Rev Date: --	URL No: TC120602400001403F
Test Report No: DSRI/ETL/1403/24	Prepared by:

Test results refer to the documented test samples only. Test report shall not be reproduced except in full, without written approval of the laboratory. Sample has been provided by the customer and the results apply to the sample as received. Sample description in all cases in taken as described by the customer.



DEFENSE SYSTEMS RESEARCH INSTITUTE

Accredited by ISO / IEC 17025 : 2017 (NABL)

Lab Location : DSRI Labs Private Limited, Plot No 21, Road Number 4, IE, Nacharam, Road,
IDA Mallapur, Hyderabad - 500 076, Telangana, Website : <https://dsri.co.in> Email : info@dsri.co.in



TEST REPORT

Test Results

Opeing Deg	T in Degree	ρ_1 (kg/m ³)	(ρ_1/ρ_0)	ΔP (PSI)	Q (GPM)	N1	cv	mean CV
90.00	29.5	996.1	0.9961	1	92	1	91.82	58.00
90.00	29.5	996.1	0.9961	2	74	1	52.22	
90.00	29.5	996.1	0.9961	3	52	1	29.96	
80.00	29.5	996.2	0.9962	1	84	1	83.84	52.93
80.00	29.5	996.2	0.9962	2	67	1	47.29	
80.00	29.5	996.2	0.9962	3	48	1	27.66	
70.00	29.7	996.3	0.9963	1	76	1	75.86	46.42
70.00	29.7	996.3	0.9963	2	58	1	40.94	
70.00	29.7	996.3	0.9963	3	39	1	22.47	
60.00	29.7	996.4	0.9964	1	69	1	68.87	39.35
60.00	29.7	996.4	0.9964	2	46	1	32.46	
60.00	29.7	996.4	0.9964	3	29	1	16.71	
50.00	29.6	996.1	0.9961	1	59	1	58.88	32.60
50.00	29.6	996.1	0.9961	2	38	1	26.82	
50.00	29.6	996.1	0.9961	3	21	1	12.10	
40.00	29.6	996.2	0.9962	1	48	1	47.91	26.48
40.00	29.6	996.2	0.9962	2	30	1	21.17	
40.00	29.6	996.2	0.9962	3	18	1	10.37	
30.00	29.8	997.1	0.9971	1	37	1	36.95	19.61
30.00	29.8	997.1	0.9971	2	22	1	15.53	
30.00	29.8	997.1	0.9971	3	11	1	6.34	
20.00	29.8	997.2	0.9972	1	23	1	22.97	11.44
20.00	29.8	997.2	0.9972	2	12	1	8.47	
20.00	29.8	997.2	0.9972	3	5	1	2.88	

****END OF REPORT****

DSRI/F/64 Issue no: 02, Issue Date: 22-07-2024 Rev. no: 00, Rev Date: --	URL No: TC120602400001403F
Test Report No: DSRI/ETL/1403/24	Prepared by:

Test results refer to the documented test samples only. Test report shall not be reproduced except in full, without written approval of the laboratory. Sample has been provided by the customer and the results apply to the sample as received. Sample description in all cases in taken as described by the customer.



DEFENSE SYSTEMS RESEARCH INSTITUTE

Accredited by ISO / IEC 17025 : 2017 (NABL)

Lab Location : DSRI Labs Private Limited, Plot No 21, Road Number 4, IE, Nacharam, Road,
IDA Mallapur, Hyderabad - 500 076, Telangana, Website : <https://dsri.co.in> Email : info@dsri.co.in

JOINT INSPECTION REPORT FOR PIPE WRACKING TEST

Test conducted date: 19-07-2024

Report issued date: 19-07-2024

Report NO.: DSRI/Rappid/Screw Down Non-Return Straight Valve/40NB/Pipe
Wracking-1

SI No.	Contents	Description
01	Client:	M/s. Rappid Valves (India) Private Limited
02	P.O No:	
03	Test Item:	40NB/PN10 Screw Down Non-Return Straight Valve Flanged Ends
04	S. No & Heat No.:	CIO970; 92-06
05	Material:	WCB
06	Drawing No.:	RV/SDNR/FLG/001
07	Pressure Gauge used:	Pressure gauge (70bar & 1000bar)
08	Serial Number/ Id No.:	1000bar_ Serial no: H230757 70 Bar_ ID. No: NMSRI/WI-PG-070
09	Due Of Calibration:	Serial no: H230757_02-10-2023 ID. No: NMSRI/WI-PG-070_02-09-2024
10	Bending stress applied:	5.3bar
11	Working pressure:	10bar
12	Test for time duration:	120sec
13	Observation:	Post application of bending stress 5.3bar above Valve. There are no cracks /surface defects deformations found by visual inspection.

Test Engineer



B. Ravi Kumar
DSRI Labs Pvt. Ltd., (LAB)



DEFENSE SYSTEMS RESEARCH INSTITUTE

Accredited by ISO / IEC 17025 : 2017 (NABL)

Lab Location : DSRI Labs Private Limited, Plot No 21, Road Number 4, IE, Nacharam, Road,
IDA Mallapur, Hyderabad - 500 076, Telangana, Website : <https://dsri.co.in> Email : info@dsri.co.in

Test Figures:



Figure 1: 40NB PN10 PIPE WRACKING SETUP



DEFENSE SYSTEMS RESEARCH INSTITUTE

Accredited by ISO / IEC 17025 : 2017 (NABL)

Lab Location : DSRI Labs Private Limited, Plot No 21, Road Number 4, IE, Nacharam, Road,
IDA Mallapur, Hyderabad - 500 076, Telangana, Website : <https://dsri.co.in> Email : info@dsri.co.in



TEST REPORT

- 01 **Test Report No:** DSRI/ETL/1405/24
- 02 **Date of Receipt:** 22nd July 2024
- 03 **Nomenclature of item tested:** 40NB PN10 Screw Down Non-Return Straight Valve (WCB)
Valve SI. No : CI0971
- 04 **Serial No:** Drawing No. : RV/SDNR/FLG/001
Body Heat No : 92-06
- 05 **Quantity:** 01
- 06 **Testing requested by:** M/s. Rappid Valves, Genesis Industrial Complex, Plot 30 & 31 Village Kolgaon, Palghar east, District-palghar, Maharashtra 401404, India.
- 07 **Manufactured by:** M/s. Rappid Valves (India) Pvt. Ltd. District-Palghar, Maharashtra.
- 08 **Test Name:** Shock test
- 09 **Test Standard:** NSS II
- 10 **Test starting date:** 18th July 2024
- 11 **Test completion date:** 18th July 2024
- 12 **Date of Issue:** 22nd July 2024

Authorized By

A. Prasant Gopal
Managing Director, DSRI

DSRI/F/64 Issue no: 02, Issue Date: 22-07-2024 Rev. no: 00, Rev Date: --	URL No: TC120602400001405F
Test Report No: DSRI/ETL/1405/24	Prepared by:

Test results refer to the documented test samples only. Test report shall not be reproduced except in full, without written approval of the laboratory. Sample has been provided by the customer and the results apply to the sample as received. Sample description in all cases in taken as described by the customer.



TEST REPORT

- 13 Test Request Control No& Date:** 1405/24, 22nd July 2024
- 14 Test Specification** Acceleration : 274g
Pule Duration : 3.5msec,
One shock per direction.
- 15 UUT Condition:** Good
- 16 Unique ID No. of Test Item:** DSRI/ETL/24/461/01
- 17 Environmental Conditions:** Temp: 34.8°C, Humidity: 50.5%RH
- 18 Test carried out at:** ET LAB
- 19 Deviation if any:** No Deviation
- 20 Equipment Used for test**
- 21 Nomenclature:** Shock Test Machine
Make/Model: NMSRI/TSTS-1010S
Calibration Validity: 10th September 2024
- 22 Test Setup:** The 40NB PN10 Screw Down Non-Return Straight Valve, SI. No: CI0971, manufactured by M/s Rappid Valves (India) Pvt. Ltd., been fixed to shock machine along with dedicated fixture in "As Fitted Condition".
- 23 Test Procedure:** Unit Under Test and accelerometer was mounted on the fixture as shown in figure and test was carried out as per the test method and standard for the required test specification.
- 24 Observation:** No structural deformity or damage was found during and after the test.
- 25 Conclusion:** The condition of UUT was found to be satisfactory upon visual inspection.

DSRI/F/64 Issue no: 02, Issue Date: 22-07-2024 Rev. no: 00, Rev Date: --	URL No: TC120602400001405F
Test Report No: DSRI/ETL/1405/24	Prepared by:

Test results refer to the documented test samples only. Test report shall not be reproduced except in full, without written approval of the laboratory. Sample has been provided by the customer and the results apply to the sample as received. Sample description in all cases in taken as described by the customer.



TEST REPORT

Test Figure:




Figure-1: 40NB PN10 Screw Down Non-Return Straight Valve

DSRI/F/64 Issue no: 02, Issue Date: 22-07-2024 Rev. no: 00, Rev Date: --	URL No: TC120602400001405F
Test Report No: DSRI/ETL/1405/24	Prepared by:

Test results refer to the documented test samples only. Test report shall not be reproduced except in full, without written approval of the laboratory. Sample has been provided by the customer and the results apply to the sample as received. Sample description in all cases in taken as described by the customer.



TEST REPORT

Test Graphs:




Fig-2: 274g for 3.5msec

****END OF REPORT****

DSRI/F/64 Issue no: 02, Issue Date: 22-07-2024 Rev. no: 00, Rev Date: --	URL No: TC120602400001405F
Test Report No: DSRI/ETL/1405/24	Prepared by:

Test results refer to the documented test samples only. Test report shall not be reproduced except in full, without written approval of the laboratory. Sample has been provided by the customer and the results apply to the sample as received. Sample description in all cases in taken as described by the customer.



DEFENSE SYSTEMS RESEARCH INSTITUTE

Accredited by ISO / IEC 17025 : 2017 (NABL)

Lab Location : DSRI Labs Private Limited, Plot No 21, Road Number 4, IE, Nacharam, Road,
IDA Mallapur, Hyderabad - 500 076, Telangana, Website : <https://dsri.co.in> Email : info@dsri.co.in

JOINT INSPECTION REPORT FOR TORQUE TEST

Test conducted date: 19-07-2024

Report issued date: 19-07-2024

**Report NO.: DSRI/Rappid/Screw Down Non-Return Straight Valve/40NB/Torque
Test-3**

Sl No.	Contents	Description
01	Client:	M/s. Rappid Valves (India) Private Limited
02	P.O No:	
03	Test Item:	40NB/PN10 Screw Down Non-Return Straight Valve Flanged Ends
04	S. No & Heat No.:	CIO971; 92-06
05	Material:	WCB
06	Drawing No.:	RV/SDNR/FLG/001
07	Torque Wrench	
	Make/Model no.:	Griphold_GTW_50
	Range: Calib due date:	14-68 Nm; 06-10-2023 05-10-2024
08	Pressure Gauge used:	Pressure gauge (0-21bars)
09	Serial Number/ Id No.:	0-21bars_ Serial no: ECPL/M/P/11
		ID. No: NMSRI/WI-PG-070
10	Due Of Calibration:	Serial no: ECPL/M/P/11_09-09-2023
		ID. No: NMSRI/WI-PG-021_08-09-2024
11	Closing Torque:	30 N-m
12	Opening Torque:	32 N-m
13	Delay Torque Time:	2sec
14	Observation:	During the hydrostatic torque test at 10 bar pressure, the opening torque was measured at 32 Nm, the closing torque at 30 Nm, and the delay torque time is 2sec. These values indicate the valve's performance under pressure, ensuring its reliability and functionality in the system.

Test Engineer

B. Ravi Kumar
DSRI Labs Pvt. Ltd., (LAB)





DEFENSE SYSTEMS RESEARCH INSTITUTE

Accredited by ISO / IEC 17025 : 2017 (NABL)

Lab Location : DSRI Labs Private Limited, Plot No 21, Road Number 4, IE, Nacharam, Road,
IDA Mallapur, Hyderabad - 500 076, Telangana, Website : <https://dsri.co.in> Email : info@dsri.co.in

Test Figure:



Figure 1: 40NB PN10 TORQUE TEST SETUP



DEFENSE SYSTEMS RESEARCH INSTITUTE

Accredited by ISO / IEC 17025 : 2017 (NABL)

Lab Location : DSRI Labs Private Limited, Plot No 21, Road Number 4, IE, Nacharam, Road,
IDA Mallapur, Hyderabad - 500 076, Telangana, Website : <https://dsri.co.in> Email : info@dsri.co.in



TEST REPORT

01	Test Report No:	DSRI/ETL/1349/24
02	Date of Receipt:	18 th July 2024
03	Nomenclature of item tested:	50NB PN10 GLOBE VALVE FANGED END (NAB)
04	Serial No.:	Valve Sl. No : CO2924 Drawing No. : RV/GBV/FLG/002 Body Heat No : 2524
05	Quantity:	01 Unit
06	Testing requested by:	M/s. Rappid Valves, Genesis Industrial Complex, Plot 30 & 31 Village Kolgaon, Palghar east, District-palghar, Maharashtra 401404, India.
07	Manufactured by:	M/s. Rappid Valves (India) Pvt. Ltd. District-Palghar, Maharashtra.
08	Test Name:	Flow Coefficient Test & Pressure Drop Test
09	Test Standard:	ANSI/ISA-A75.01
10	Test starting date:	18 th July 2024
11	Test completion date:	18 th July 2024
12	Date of Issue:	18 th July 2024

Authorized By



A. Prasant Gopal

Managing Director, DSRI

DSRI/F/64 Issue no: 02, Issue Date: 18-07-2024 Rev. no: 00, Rev Date: --	URL No: TC120602400001349F
Test Report No: DSRI/ETL/1349/24	Prepared by:

Test results refer to the documented test samples only. Test report shall not be reproduced except in full, without written approval of the laboratory. Sample has been provided by the customer and the results apply to the sample as received. Sample description in all cases in taken as described by the customer.



TEST REPORT

- 13 **Test Request Control No& Date:** 1349/24, 18th Jul 2024
- 14 **Test Specification** As per the standard
- 15 **UUT Condition:** Good
- 16 **Unique ID No. of Test Item:** DSRI/ETL/24/447/01
- 17 **Environmental Conditions:** Temp: 36.8°C, Humidity: 54.8%RH
- 18 **Test carried out at:** ET LAB
- 19 **Deviation if any:** No Deviation
- 20 **Equipment Used for test**
 - Nomenclature:** Ultrasonic Flow meter
 - Make/Model:** ADEPT/UFM 6720
 - Calibration Validity:** 24th February 2025
 - Pressure Gauges used**
 - Pressure gauge -I : 053533692493
 - Pressure gauge –II : 053860344134
 - Pressure gauge range: 0 to 2 Bar
 - Calibration Validity : 13th Jun 2025
- 21 **Test Setup:** Flow coefficient test setup is carried out as shown in the fig
- 22 **Test Procedure:** Set up the pressure gauges and flow meter in their designated locations according to the test specifications. Position the valve in the fully open state and measure both the flow rate and the pressure drop (Δp) across the valve. Record the inlet water temperature. Adjust the valve to various openings and measure the flow rate and pressure drop (Δp) for each setting. Perform each measurement at least three times to ensure accuracy and consistency.

DSRI/F/64 Issue no: 02, Issue Date: 18-07-2024 Rev. no: 00, Rev Date: --	URL No: TC120602400001349F
Test Report No: DSRI/ETL/1349/24	Prepared by:

Test results refer to the documented test samples only. Test report shall not be reproduced except in full, without written approval of the laboratory. Sample has been provided by the customer and the results apply to the sample as received. Sample description in all cases in taken as described by the customer.



TEST REPORT

- 23 Observation:** No structural deformity or damage was found during and after the test.
- 24 Conclusion:** Flow coefficient test for the unit '50NB PN10 Globe Valve Fanged End Sl. No: CO2924 and Quantity: 01' is completed as per test specification conforming to the test method and standard of this report and unit condition is good as before the test

Test Figure:



DSRI/F/64 Issue no: 02, Issue Date: 18-07-2024 Rev. no: 00, Rev Date: --	URL No: TC120602400001349F
Test Report No: DSRI/ETL/1349/24	Prepared by:

Test results refer to the documented test samples only. Test report shall not be reproduced except in full, without written approval of the laboratory. Sample has been provided by the customer and the results apply to the sample as received. Sample description in all cases in taken as described by the customer.



DEFENSE SYSTEMS RESEARCH INSTITUTE

Accredited by ISO / IEC 17025 : 2017 (NABL)

Lab Location : DSRI Labs Private Limited, Plot No 21, Road Number 4, IE, Nacharam, Road,
IDA Mallapur, Hyderabad - 500 076, Telangana, Website : <https://dsri.co.in> Email : info@dsri.co.in



TEST REPORT

Test Results

Opening Deg	T in Degree	ρ_1 (kg/m ³)	(ρ_1/ρ_0)	ΔP (PSI)	Q (GPM)	N1	cv	mean CV
90.00	29.3	996.1	0.9961	2	118	1	83.28	50.16
90.00	29.3	996.1	0.9961	4	81	1	40.42	
90.00	29.3	996.1	0.9961	5	60	1	26.78	
80.00	29.3	996.1	0.9961	2	114	1	80.46	48.42
80.00	29.3	996.1	0.9961	4	78	1	38.93	
80.00	29.3	996.1	0.9961	5	58	1	25.89	
70.00	29.4	996.3	0.9963	2	104	1	73.40	43.03
70.00	29.4	996.3	0.9963	4	74	1	36.93	
70.00	29.4	996.3	0.9963	5	42	1	18.75	
60.00	29.4	996.2	0.9962	2	96	1	67.75	38.82
60.00	29.4	996.2	0.9962	4	69	1	34.43	
60.00	29.4	996.2	0.9962	5	32	1	14.28	
50.00	29.6	996.2	0.9962	2	84	1	59.28	31.81
50.00	29.6	996.2	0.9962	4	51	1	25.45	
50.00	29.6	996.2	0.9962	5	24	1	10.71	
40.00	29.6	996.2	0.9962	2	71	1	50.11	25.77
40.00	29.6	996.2	0.9962	4	42	1	20.96	
40.00	29.6	996.2	0.9962	5	14	1	6.25	
20.00	29.9	997.4	0.9974	2	61	1	43.07	21.52
20.00	29.9	997.4	0.9974	4	35	1	17.47	
20.00	29.9	997.4	0.9974	5	9	1	4.02	

****END OF REPORT****

DSRI/F/64 Issue no: 02, Issue Date: 18-07-2024 Rev. no: 00, Rev Date: --	URL No: TC120602400001349F
Test Report No: DSRI/ETL/1349/24	Prepared by:

Test results refer to the documented test samples only. Test report shall not be reproduced except in full, without written approval of the laboratory. Sample has been provided by the customer and the results apply to the sample as received. Sample description in all cases in taken as described by the customer.



DEFENSE SYSTEMS RESEARCH INSTITUTE

Accredited by ISO / IEC 17025 : 2017 (NABL)

Lab Location : DSRI Labs Private Limited, Plot No 21, Road Number 4, IE, Nacharam, Road,
IDA Mallapur, Hyderabad - 500 076, Telangana, Website : <https://dsri.co.in> Email : info@dsri.co.in



TEST REPORT

01	Test Report No:	DSRI/ETL/1352/24
02	Date of Receipt:	18 th Jul 2024
03	Nomenclature of item tested:	50NB PN10 GLOBE VALVE FANGED END(NAB) Valve Sl. No : CO2924
04	Serial No:	Drawing No. : RV/GBV/FLG/002 Body Heat No : 2524
05	Quantity:	01
06	Testing requested by:	M/s. Rappid Valves, Genesis Industrial Complex, Plot 30 & 31 Village Kolgaon, Palghar east, District-palghar, Maharashtra 401404, India.
07	Manufactured by:	Rappid Valves (India) Pvt. Ltd. District-Palghar, Maharashtra 401404.
08	Test Name:	Shock test
09	Test Standard:	NSS II
10	Test starting date:	18 th JUL 2024
11	Test completion date:	18 th JUL 2024
12	Date of Issue:	18 th JUL 2024

Authorized By



A. Prasant Gopal
Managing Director, DSRI

DSRI/F/64 Issue no: 02, Issue Date: 18-07-2024 Rev. no: 00, Rev Date: --	URL No: TC120602400001352P
Test Report No: DSRI/ETL/1352/24	Prepared by:

Test results refer to the documented test samples only. Test report shall not be reproduced except in full, without written approval of the laboratory. Sample has been provided by the customer and the results apply to the sample as received. Sample description in all cases in taken as described by the customer.



TEST REPORT

- 13 Test Request Control No& Date:** 1352/24, 18th JUL 2024
- 14 Test Specification** Acceleration : 280g
Pule Duration : 3.9msec,
One shock per direction.
- 15 UUT Condition:** Good
- 16 Unique ID No. of Test Item:** DSRI/ETL/24/447/01
- 17 Environmental Conditions:** Temp: 34.8°C, Humidity: 50.5%RH
- 18 Test carried out at:** ET LAB
- 19 Deviation if any:** No Deviation
- 20 Equipment Used for test**
- 21 Nomenclature:** Shock Test Machine
Make/Model: NMSRI/TSTS-1010S
Calibration Validity: 10th September 2024
- 22 Test Setup:** The 50NB PN10 Globe Valve Fanged End, Sl. No: CO2924, manufactured by M/s Rappid Valves (India) Pvt. Ltd., been fixed to shock machine along with dedicated fixture in "As Fitted Condition".
- 23 Test Procedure:** Unit Under Test and accelerometer was mounted on the fixture as shown in figure and test was carried out as per the test method and standard for the required test specification.
- 24 Observation:** No structural deformity or damage was found during and after the test.
- 25 Conclusion:** The condition of UUT was found to be satisfactory upon visual inspection.

DSRI/F/64 Issue no: 02, Issue Date: 18-07-2024 Rev. no: 00, Rev Date: --	URL No: TC120602400001352P
Test Report No: DSRI/ETL/1352/24	Prepared by:

Test results refer to the documented test samples only. Test report shall not be reproduced except in full, without written approval of the laboratory. Sample has been provided by the customer and the results apply to the sample as received. Sample description in all cases in taken as described by the customer.



TEST REPORT

TEST FIGURE:



Figure-1: 50NB PN10 GLOBE VALVE FANGED END

DSRI/F/64 Issue no: 02, Issue Date: 18-07-2024 Rev. no: 00, Rev Date: --	URL No: TC120602400001352P
Test Report No: DSRI/ETL/1352/24	Prepared by:

Test results refer to the documented test samples only. Test report shall not be reproduced except in full, without written approval of the laboratory. Sample has been provided by the customer and the results apply to the sample as received. Sample description in all cases in taken as described by the customer.



TEST REPORT

Test Graphs:




Fig-2: 276g for 3.4msec

****END OF REPORT****

DSRI/F/64 Issue no: 02, Issue Date: 18-07-2024 Rev. no: 00, Rev Date: --	URL No: TC120602400001352P
Test Report No: DSRI/ETL/1352/24	Prepared by:

Test results refer to the documented test samples only. Test report shall not be reproduced except in full, without written approval of the laboratory. Sample has been provided by the customer and the results apply to the sample as received. Sample description in all cases in taken as described by the customer.



DEFENSE SYSTEMS RESEARCH INSTITUTE

Accredited by ISO / IEC 17025 : 2017 (NABL)

Lab Location : DSRI Labs Private Limited, Plot No 21, Road Number 4, IE, Nacharam, Road,
IDA Mallapur, Hyderabad - 500 076, Telangana, Website : <https://dsri.co.in> Email : info@dsri.co.in



TEST REPORT

01	Test Report No:	DSRI/ETL/1400/24
02	Date of Receipt:	22 nd July 2024
03	Nomenclature of item tested:	50NB PN16 Screw Down Non-Return Straight Valve (WCB) Valve Sl. No : CI0969
04	Serial No.:	Drawing No. : RV/SDNR/FLG/001 Body Heat No : 92-06
05	Quantity:	01 Unit
06	Testing requested by:	M/s. Rappid Valves, Genesis Industrial Complex, Plot 30 & 31 Village Kolgaon, Palghar east, District-palghar, Maharashtra 401404, India.
07	Manufactured by:	M/s. Rappid Valves (India) Pvt. Ltd. District-Palghar, Maharashtra.
08	Test Name:	Flow Coefficient Test & Pressure Drop Test
09	Test Standard:	ANSI/ISA-A75.01
10	Test starting date:	18 th July 2024
11	Test completion date:	18 th July 2024
12	Date of Issue:	22 nd July 2024

Authorized By

A. Prasant Gopal

Managing Director, DSRI



DSRI/F/64 Issue no: 02, Issue Date: 22-07-2024 Rev. no: 00, Rev Date: --	URL No: TC120602400001400F
Test Report No: DSRI/ETL/1400/24	Prepared by:

Test results refer to the documented test samples only. Test report shall not be reproduced except in full, without written approval of the laboratory. Sample has been provided by the customer and the results apply to the sample as received. Sample description in all cases in taken as described by the customer.



TEST REPORT

- 13 **Test Request Control No& Date:** 1400/24, 22nd Jul 2024
- 14 **Test Specification** As per the standard
- 15 **UUT Condition:** Good
- 16 **Unique ID No. of Test Item:** DSRI/ETL/24/460/01
- 17 **Environmental Conditions:** Temp: 36.8°C, Humidity: 54.8%RH
- 18 **Test carried out at:** ET LAB
- 19 **Deviation if any:** No Deviation
- 20 **Equipment Used for test**
 - Nomenclature:** Ultrasonic Flow meter
 - Make/Model:** ADEPT/UFM 6720
 - Calibration Validity:** 24th February 2025
 - Pressure Gauges used**
 - Pressure gauge -I : 053533692493
 - Pressure gauge –II : 053860344134
 - Pressure gauge range: 0 to 2 Bar
 - Calibration Validity : 13th Jun 2025
- 21 **Test Setup:** Flow coefficient test setup is carried out as shown in the fig
- 22 **Test Procedure:** Set up the pressure gauges and flow meter in their designated locations according to the test specifications. Position the valve in the fully open state and measure both the flow rate and the pressure drop (Δp) across the valve. Record the inlet water temperature. Adjust the valve to various openings and measure the flow rate and pressure drop (Δp) for each setting. Perform each measurement at least three times to ensure accuracy and consistency.

DSRI/F/64 Issue no: 02, Issue Date: 22-07-2024 Rev. no: 00, Rev Date: --	URL No: TC120602400001400F
Test Report No: DSRI/ETL/1400/24	Prepared by:

Test results refer to the documented test samples only. Test report shall not be reproduced except in full, without written approval of the laboratory. Sample has been provided by the customer and the results apply to the sample as received. Sample description in all cases in taken as described by the customer.



TEST REPORT

23 Observation:

No structural deformity or damage was found during and after the test.

24 Conclusion:

Flow coefficient test for the unit '50NB PN16 Screw Down Non-Return Straight Valve Sl. No: CI0969 and Quantity: 01' is completed as per test specification conforming to the test method and standard of this report and unit condition is good as before the test

Test Figure:



DSRI/F/64 Issue no: 02, Issue Date: 22-07-2024 Rev. no: 00, Rev Date: --	URL No: TC120602400001400F
Test Report No: DSRI/ETL/1400/24	Prepared by:

Test results refer to the documented test samples only. Test report shall not be reproduced except in full, without written approval of the laboratory. Sample has been provided by the customer and the results apply to the sample as received. Sample description in all cases in taken as described by the customer.



TEST REPORT

Test Results

Opeing Deg	T in Degree	ρ_1 (kg/m3)	(ρ_1/ρ_0)	ΔP (PSI)	Q (GPM)	N1	cv	mean CV
90.00	29.5	996.1	0.9961	1	175	1	66.01	48.24
90.00	29.5	996.1	0.9961	2	142	1	50.11	
90.00	29.5	996.1	0.9961	3	86	1	28.61	
80.00	29.5	996.2	0.9962	1	154	1	58.10	42.88
80.00	29.5	996.2	0.9962	2	132	1	46.58	
80.00	29.5	996.2	0.9962	3	72	1	23.95	
70.00	29.7	996.3	0.9963	1	136	1	51.31	38.81
70.00	29.7	996.3	0.9963	2	127	1	44.82	
70.00	29.7	996.3	0.9963	3	61	1	20.30	
60.00	29.7	996.4	0.9964	1	125	1	47.16	32.68
60.00	29.7	996.4	0.9964	2	98	1	34.59	
60.00	29.7	996.4	0.9964	3	49	1	16.30	
50.00	29.6	996.5	0.9965	1	112	1	42.25	27.97
50.00	29.6	996.5	0.9965	2	86	1	30.35	
50.00	29.6	996.5	0.9965	3	34	1	11.31	
40.00	29.6	997.1	0.9971	1	96	1	36.22	17.69
40.00	29.6	997.1	0.9971	2	28	1	9.88	
40.00	29.6	997.1	0.9971	3	21	1	6.99	
30.00	29.8	997.2	0.9972	1	78	1	29.44	14.19
30.00	29.8	997.2	0.9972	2	24	1	8.47	
30.00	29.8	997.2	0.9972	3	14	1	4.66	
20.00	29.8	997.3	0.9973	1	66	1	24.91	11.99
20.00	29.8	997.3	0.9973	2	20	1	7.06	
20.00	29.8	997.3	0.9973	3	12	1	3.99	

****END OF REPORT****

DSRI/F/64 Issue no: 02, Issue Date: 22-07-2024 Rev. no: 00, Rev Date: --	URL No: TC120602400001400F
Test Report No: DSRI/ETL/1400/24	Prepared by:

Test results refer to the documented test samples only. Test report shall not be reproduced except in full, without written approval of the laboratory. Sample has been provided by the customer and the results apply to the sample as received. Sample description in all cases in taken as described by the customer.



DEFENSE SYSTEMS RESEARCH INSTITUTE

Accredited by ISO / IEC 17025 : 2017 (NABL)

Lab Location : DSRI Labs Private Limited, Plot No 21, Road Number 4, IE, Nacharam, Road,
IDA Mallapur, Hyderabad - 500 076, Telangana, Website : <https://dsri.co.in> Email : info@dsri.co.in

JOINT INSPECTION REPORT FOR PIPE WRACKING TEST

Test conducted date: 19-07-2024

Report issued date: 19-07-2024

Report NO.: DSRI/Rappid/Screw Down Non-Return Straight Valve/50NB/Pipe
Wracking-2

SI No.	Contents	Description
01	Client:	M/s. Rappid Valves (India) Private Limited
02	P.O No:	
03	Test Item:	50NB/PN16 Screw Down Non-Return Straight Valve Flanged Ends
04	S. No & Heat No.:	CIO969; 92-06
05	Material:	WCB
06	Drawing No.:	RV/SDNR/FLG/001
07	Pressure Gauge used:	Pressure gauge (70bar & 1000bar)
08	Serial Number/ Id No.:	1000bar_ Serial no: H230757 70 Bar_ ID. No: NMSRI/WI-PG-070
09	Due Of Calibration:	Serial no: H230757_02-10-2023 ID. No: NMSRI/WI-PG-070_02-09-2024
10	Bending stress applied:	5.5bar
11	Working pressure:	10bar
12	Test for time duration:	120sec
13	Observation:	Post application of bending stress 5.5bar above Valve. There are no cracks /surface defects deformations found by visual inspection.

Test Engineer



B. Ravi Kumar
DSRI Labs Pvt. Ltd., (LAB)



DEFENSE SYSTEMS RESEARCH INSTITUTE

Accredited by ISO / IEC 17025 : 2017 (NABL)

Lab Location : DSRI Labs Private Limited, Plot No 21, Road Number 4, IE, Nacharam, Road,
IDA Mallapur, Hyderabad - 500 076, Telangana, Website : <https://dsri.co.in> Email : info@dsri.co.in

Test Figures:



Figure 1: 50NB PN16 PIPE WRACKING SETUP



DEFENSE SYSTEMS RESEARCH INSTITUTE

Accredited by ISO / IEC 17025 : 2017 (NABL)

Lab Location : DSRI Labs Private Limited, Plot No 21, Road Number 4, IE, Nacharam, Road,
IDA Mallapur, Hyderabad - 500 076, Telangana, Website : <https://dsri.co.in> Email : info@dsri.co.in

JOINT INSPECTION REPORT FOR PIPE WRACKING TEST

Test conducted date: 19-07-2024

Report issued date: 19-07-2024

Report NO.: DSRI/Rappid/Globe Valve Flanged Ends/50NB/Pipe Wracking-4

SI No.	Contents	Description
01	Client:	M/s. Rappid Valves (India) Private Limited
02	P.O No:	
03	Test Item:	50NB/PN10 Globe Valve Flanged Ends
04	S. No & Heat No.:	CO2924; 2524
05	Material:	NAB
06	Drawing No.:	RV/GBV/FLG/002
07	Pressure Gauge used:	Pressure gauge (70bar & 1000bar)
08	Serial Number/ Id No.:	1000bar_ Serial no: H230757 70 Bar_ ID. No: NMSRI/WI-PG-070
09	Due Of Calibration:	Serial no: H230757_02-10-2023 ID. No: NMSRI/WI-PG-070_02-09-2024
10	Bending stress applied:	5.8bar
11	Working pressure:	10bar
12	Test for time duration:	120sec
13	Observation:	Post application of bending stress 5.8bar above Valve. There are no cracks /surface defects deformations found by visual inspection.

Test Engineer



B. Ravi Kumar
DSRI Labs Pvt. Ltd., (LAB)



DEFENSE SYSTEMS RESEARCH INSTITUTE

Accredited by ISO / IEC 17025 : 2017 (NABL)

Lab Location : DSRI Labs Private Limited, Plot No 21, Road Number 4, IE, Nacharam, Road,
IDA Mallapur, Hyderabad - 500 076, Telangana, Website : <https://dsri.co.in> Email : info@dsri.co.in

Test Figures:



Figure 1: 50NB PN10 PIPE WRACKING SETUP



DEFENSE SYSTEMS RESEARCH INSTITUTE

Accredited by ISO / IEC 17025 : 2017 (NABL)

Lab Location : DSRI Labs Private Limited, Plot No 21, Road Number 4, IE, Nacharam, Road,
IDA Mallapur, Hyderabad - 500 076, Telangana, Website : <https://dsri.co.in> Email : info@dsri.co.in



TEST REPORT

01	Test Report No:	DSRI/ETL/1402/24
02	Date of Receipt:	22 nd July 2024
03	Nomenclature of item tested:	50NB PN16 Screw Down Non-Return Straight Valve (WCB) Valve SI. No : CI0969
04	Serial No:	Drawing No. : RV/SDNR/FLG/001 Body Heat No : 92-06
05	Quantity:	01
06	Testing requested by:	M/s. Rappid Valves, Genesis Industrial Complex, Plot 30 & 31 Village Kolgaon, Palghar east, District-palghar, Maharashtra 401404, India.
07	Manufactured by:	M/s. Rappid Valves (India) Pvt. Ltd. District-Palghar, Maharashtra.
08	Test Name:	Shock test
09	Test Standard:	NSS II
10	Test starting date:	18 th July 2024
11	Test completion date:	18 th July 2024
12	Date of Issue:	22 nd July 2024

Authorized By



A. Prasant Gopal
Managing Director, DSRI

DSRI/F/64 Issue no: 02, Issue Date: 22-07-2024 Rev. no: 00, Rev Date: --	URL No: TC120602400001402F
Test Report No: DSRI/ETL/1402/24	Prepared by:

Test results refer to the documented test samples only. Test report shall not be reproduced except in full, without written approval of the laboratory. Sample has been provided by the customer and the results apply to the sample as received. Sample description in all cases in taken as described by the customer.



TEST REPORT

- 13 Test Request Control No& Date:** 1402/24, 22nd July 2024
- 14 Test Specification** Acceleration : 279g
Pule Duration : 3.5msec,
One shock per direction.
- 15 UUT Condition:** Good
- 16 Unique ID No. of Test Item:** DSRI/ETL/24/460/01
- 17 Environmental Conditions:** Temp: 34.8°C, Humidity: 50.5%RH
- 18 Test carried out at:** ET LAB
- 19 Deviation if any:** No Deviation
- 20 Equipment Used for test**
- 21 Nomenclature:** Shock Test Machine
Make/Model: NMSRI/TSTS-1010S
Calibration Validity: 10th September 2024
- 22 Test Setup:** The 50NB PN16 Screw Down Non-Return Straight Valve, Sl. No: CI0969, manufactured by M/s Rappid Valves (India) Pvt. Ltd., been fixed to shock machine along with dedicated fixture in "As Fitted Condition".
- 23 Test Procedure:** Unit Under Test and accelerometer was mounted on the fixture as shown in figure and test was carried out as per the test method and standard for the required test specification.
- 24 Observation:** No structural deformity or damage was found during and after the test.
- 25 Conclusion:** The condition of UUT was found to be satisfactory upon visual inspection.

DSRI/F/64 Issue no: 02, Issue Date: 22-07-2024 Rev. no: 00, Rev Date: --	URL No: TC120602400001402F
Test Report No: DSRI/ETL/1402/24	Prepared by:

Test results refer to the documented test samples only. Test report shall not be reproduced except in full, without written approval of the laboratory. Sample has been provided by the customer and the results apply to the sample as received. Sample description in all cases in taken as described by the customer.



TEST REPORT

Test Figure:




Figure-1: 50NB PN16 Screw Down Non-Return Straight Valve

DSRI/F/64 Issue no: 02, Issue Date: 22-07-2024 Rev. no: 00, Rev Date: --	URL No: TC120602400001402F
Test Report No: DSRI/ETL/1402/24	Prepared by:

Test results refer to the documented test samples only. Test report shall not be reproduced except in full, without written approval of the laboratory. Sample has been provided by the customer and the results apply to the sample as received. Sample description in all cases in taken as described by the customer.



TEST REPORT

Test Graphs:




Fig-2: 279g for 3.5msec

****END OF REPORT****

DSRI/F/64 Issue no: 02, Issue Date: 22-07-2024 Rev. no: 00, Rev Date: --	URL No: TC120602400001402F
Test Report No: DSRI/ETL/1402/24	Prepared by:

Test results refer to the documented test samples only. Test report shall not be reproduced except in full, without written approval of the laboratory. Sample has been provided by the customer and the results apply to the sample as received. Sample description in all cases in taken as described by the customer.



DEFENSE SYSTEMS RESEARCH INSTITUTE

Accredited by ISO / IEC 17025 : 2017 (NABL)

Lab Location : DSRI Labs Private Limited, Plot No 21, Road Number 4, IE, Nacharam, Road,
IDA Mallapur, Hyderabad - 500 076, Telangana, Website : <https://dsri.co.in> Email : info@dsri.co.in

JOINT INSPECTION REPORT FOR TORQUE TEST

Test conducted date: 19-07-2024

Report issued date: 19-07-2024

**Report NO.: DSRI/Rappid/Screw Down Non-Return Straight Valve/50NB/Torque
Test-3**

Sl No.	Contents	Description
01	Client:	M/s. Rappid Valves (India) Private Limited
02	P.O No:	
03	Test Item:	50NB/PN16 Screw Down Non-Return Straight Valve Flanged Ends
04	S. No & Heat No.:	CIO970; 92-06
05	Material:	WCB
06	Drawing No.:	RV/SDNR/FLG/001
07	Torque Wrench	
	Make/Model no.:	Griphold_GTW_50
	Range: Calib due date:	14-68 Nm; 06-10-2023 05-10-2024
08	Pressure Gauge used:	Pressure gauge (0-21bars)
09	Serial Number/ Id No.:	0-21bars_ Serial no: ECPL/M/P/11
		ID. No: NMSRI/WI-PG-070
10	Due Of Calibration:	Serial no: ECPL/M/P/11_09-09-2023
		ID. No: NMSRI/WI-PG-021_08-09-2024
11	Closing Torque:	42 N-m
12	Opening Torque:	48 N-m
13	Delay Torque Time:	2sec
14	Observation:	During the hydrostatic torque test at 10 bar pressure, the opening torque was measured at 48 Nm, the closing torque at 42 Nm, and the delay torque time is 2sec. These values indicate the valve's performance under pressure, ensuring its reliability and functionality in the system.

Test Engineer

B. Ravi Kumar
DSRI Labs Pvt. Ltd., (LA





DEFENSE SYSTEMS RESEARCH INSTITUTE

Accredited by ISO / IEC 17025 : 2017 (NABL)

Lab Location : DSRI Labs Private Limited, Plot No 21, Road Number 4, IE, Nacharam, Road,
IDA Mallapur, Hyderabad - 500 076, Telangana, Website : <https://dsri.co.in> Email : info@dsri.co.in

Test Figure:



Figure 1: 50NB PN16 TORQUE TEST SETUP



DEFENSE SYSTEMS RESEARCH INSTITUTE

Accredited by ISO / IEC 17025 : 2017 (NABL)

Lab Location : DSRI Labs Private Limited, Plot No 21, Road Number 4, IE, Nacharam, Road,
IDA Mallapur, Hyderabad - 500 076, Telangana, Website : <https://dsri.co.in> Email : info@dsri.co.in



TEST REPORT

01	Test Report No:	DSRI/ETL/1394/24
02	Date of Receipt:	22 nd July 2024
03	Nomenclature of item tested:	65NB PN10 GLOBE VALVE FANGED END (WCB)
04	Serial No.:	Valve Sl. No : CI0968 Drawing No. : RV/GBV/FLG/001 Body Heat No : 92-06
05	Quantity:	01 Unit
06	Testing requested by:	M/s. Rappid Valves, Genesis Industrial Complex, Plot 30 & 31 Village Kolgaon, Palghar east, District-palghar, Maharashtra 401404, India.
07	Manufactured by:	M/s. Rappid Valves (India) Pvt. Ltd. District-Palghar, Maharashtra.
08	Test Name:	Flow Coefficient Test & Pressure Drop Test
09	Test Standard:	ANSI/ISA-A75.01
10	Test starting date:	18 th July 2024
11	Test completion date:	18 th July 2024
12	Date of Issue:	22 nd July 2024

Authorized By



A. Prasant Gopal

Managing Director, DSRI

DSRI/F/64 Issue no: 02, Issue Date: 22-07-2024 Rev. no: 00, Rev Date: --	URL No: TC120602400001394F
Test Report No: DSRI/ETL/1394/24	Prepared by:

Test results refer to the documented test samples only. Test report shall not be reproduced except in full, without written approval of the laboratory. Sample has been provided by the customer and the results apply to the sample as received. Sample description in all cases in taken as described by the customer.



TEST REPORT

- 13 **Test Request Control No& Date:** 1394/24, 22nd Jul 2024
- 14 **Test Specification** As per the standard
- 15 **UUT Condition:** Good
- 16 **Unique ID No. of Test Item:** DSRI/ETL/24/458/01
- 17 **Environmental Conditions:** Temp: 36.8°C, Humidity: 54.8%RH
- 18 **Test carried out at:** ET LAB
- 19 **Deviation if any:** No Deviation
- 20 **Equipment Used for test**
- 21 **Nomenclature:** Ultrasonic Flow meter
Make/Model: ADEPT/UFM 6720
Calibration Validity: 24th February 2025
Pressure Gauges used Pressure gauge -I : 053533692493
Pressure gauge –II : 053860344134
Pressure gauge range: 0 to 2 Bar
Calibration Validity : 13th Jun 2025
- 22 **Test Setup:** Flow coefficient test setup is carried out as shown in the fig
- 23 **Test Procedure:** Set up the pressure gauges and flow meter in their designated locations according to the test specifications. Position the valve in the fully open state and measure both the flow rate and the pressure drop (Δp) across the valve. Record the inlet water temperature. Adjust the valve to various openings and measure the flow rate and pressure drop (Δp) for each setting. Perform each measurement at least three times to ensure accuracy and consistency.

DSRI/F/64 Issue no: 02, Issue Date: 22-07-2024 Rev. no: 00, Rev Date: --	URL No: TC120602400001394F
Test Report No: DSRI/ETL/1394/24	Prepared by:

Test results refer to the documented test samples only. Test report shall not be reproduced except in full, without written approval of the laboratory. Sample has been provided by the customer and the results apply to the sample as received. Sample description in all cases in taken as described by the customer.



TEST REPORT

24 Observation:

No structural deformity or damage was found during and after the test.

25 Conclusion:

Flow coefficient test for the unit '65NB PN10 Globe Valve Fanged End Sl. No: CI0968 and Quantity: 01' is completed as per test specification conforming to the test method and standard of this report and unit condition is good as before the test

Test Figure:



DSRI/F/64 Issue no: 02, Issue Date: 22-07-2024 Rev. no: 00, Rev Date: --	URL No: TC120602400001394F
Test Report No: DSRI/ETL/1394/24	Prepared by:

Test results refer to the documented test samples only. Test report shall not be reproduced except in full, without written approval of the laboratory. Sample has been provided by the customer and the results apply to the sample as received. Sample description in all cases in taken as described by the customer.



DEFENSE SYSTEMS RESEARCH INSTITUTE

Accredited by ISO / IEC 17025 : 2017 (NABL)

Lab Location : DSRI Labs Private Limited, Plot No 21, Road Number 4, IE, Nacharam, Road,
IDA Mallapur, Hyderabad - 500 076, Telangana, Website : <https://dsri.co.in> Email : info@dsri.co.in



TEST REPORT

Test Results

Opeing Deg	T in Degree	ρ_1 (kg/m ³)	(ρ_1/ρ_0)	ΔP (PSI)	Q (GPM)	N1	cv	mean CV
90.00	29.2	996.2	0.9962	7	147	1	55.45	43.79
90.00	29.2	996.2	0.9962	8	135	1	47.64	
90.00	29.2	996.2	0.9962	9	85	1	28.28	
80.00	29.2	996.3	0.9963	7	132	1	49.80	38.26
80.00	29.2	996.3	0.9963	8	120	1	42.35	
80.00	29.2	996.3	0.9963	9	68	1	22.62	
70.00	29.3	996.4	0.9964	7	126	1	47.54	34.30
70.00	29.3	996.4	0.9964	8	106	1	37.41	
70.00	29.3	996.4	0.9964	9	54	1	17.97	
60.00	29.3	996.2	0.9962	7	118	1	44.52	30.56
60.00	29.3	996.2	0.9962	8	94	1	33.17	
60.00	29.3	996.2	0.9962	9	42	1	13.97	
50.00	29.5	996.3	0.9963	7	102	1	38.48	25.80
50.00	29.5	996.3	0.9963	8	82	1	28.93	
50.00	29.5	996.3	0.9963	9	30	1	9.98	
40.00	29.5	996.4	0.9964	7	92	1	34.71	16.96
40.00	29.5	996.4	0.9964	8	26	1	9.17	
40.00	29.5	996.4	0.9964	9	21	1	6.99	
30.00	29.8	997.1	0.9971	7	74	1	27.93	13.79
30.00	29.8	997.1	0.9971	8	23	1	8.12	
30.00	29.8	997.1	0.9971	9	16	1	5.33	
20.00	29.8	997.2	0.9972	7	68	1	25.67	12.12
20.00	29.8	997.2	0.9972	8	19	1	6.71	
20.00	29.8	997.2	0.9972	9	12	1	3.99	

****END OF REPORT****

DSRI/F/64 Issue no: 02, Issue Date: 22-07-2024 Rev. no: 00, Rev Date: --	URL No: TC120602400001394F
Test Report No: DSRI/ETL/1394/24	Prepared by:

Test results refer to the documented test samples only. Test report shall not be reproduced except in full, without written approval of the laboratory. Sample has been provided by the customer and the results apply to the sample as received. Sample description in all cases in taken as described by the customer.



DEFENSE SYSTEMS RESEARCH INSTITUTE

Accredited by ISO / IEC 17025 : 2017 (NABL)

Lab Location : DSRI Labs Private Limited, Plot No 21, Road Number 4, IE, Nacharam, Road,
IDA Mallapur, Hyderabad - 500 076, Telangana, Website : <https://dsri.co.in> Email : info@dsri.co.in

JOINT INSPECTION REPORT FOR PIPE WRACKING TEST

Test conducted date: 19-07-2024


Report issued date: 19-07-2024

Report NO.: DSRI/Rappid/Globe Valve Flanged Ends/65NB/Pipe Wracking-3

SI No.	Contents	Description
01	Client:	M/s. Rappid Valves (India) Private Limited
02	P.O No:	
03	Test Item:	65NB/PN10 Globe Valve Flanged Ends
04	S. No & Heat No.:	CIO968; 92-06
05	Material:	WCB
06	Drawing No.:	RV/GBV/FLG/001
07	Pressure Gauge used:	Pressure gauge (70bar & 1000bar)
08	Serial Number/ Id No.:	1000bar_ Serial no: H230757 70 Bar_ ID. No: NMSRI/WI-PG-070
09	Due Of Calibration:	Serial no: H230757_02-10-2023 ID. No: NMSRI/WI-PG-070_02-09-2024
10	Bending stress applied:	5.6bar
11	Working pressure:	10bar
12	Test for time duration:	120sec
13	Observation:	Post application of bending stress 5.6bar above Valve. There are no cracks /surface defects deformations found by visual inspection.

Test Engineer

B. Ravi Kumar
DSRI Labs Pvt. Ltd., (LAB)





DEFENSE SYSTEMS RESEARCH INSTITUTE

Accredited by ISO / IEC 17025 : 2017 (NABL)

Lab Location : DSRI Labs Private Limited, Plot No 21, Road Number 4, IE, Nacharam, Road,
IDA Mallapur, Hyderabad - 500 076, Telangana, Website : <https://dsri.co.in> Email : info@dsri.co.in

Test Figures:



Figure 1: 65NB PN10 PIPE WRACKING SETUP



DEFENSE SYSTEMS RESEARCH INSTITUTE

Accredited by ISO / IEC 17025 : 2017 (NABL)

Lab Location : DSRI Labs Private Limited, Plot No 21, Road Number 4, IE, Nacharam, Road,
IDA Mallapur, Hyderabad - 500 076, Telangana, Website : <https://dsri.co.in> Email : info@dsri.co.in



TEST REPORT

01	Test Report No:	DSRI/ETL/1396/24
02	Date of Receipt:	22 nd July 2024
03	Nomenclature of item tested:	65NB PN10 GLOBE VALVE FANGED END (WCB) Valve SI. No : CI0968
04	Serial No:	Drawing No. : RV/GBV/FLG/001 Body Heat No : 92-06
05	Quantity:	01
06	Testing requested by:	M/s. Rappid Valves, Genesis Industrial Complex, Plot 30 & 31 Village Kolgaon, Palghar east, District- palghar, Maharashtra 401404, India.
07	Manufactured by:	M/s. Rappid Valves (India) Pvt. Ltd. District- Palghar, Maharashtra.
08	Test Name:	Shock test
09	Test Standard:	NSS II
10	Test starting date:	18 th July 2024
11	Test completion date:	18 th July 2024
12	Date of Issue:	22 nd July 2024

Authorized By



A. Prasant Gopal
Managing Director, DSRI

DSRI/F/64 Issue no: 02, Issue Date: 22-07-2024 Rev. no: 00, Rev Date: --	URL No: TC120602400001396F
Test Report No: DSRI/ETL/1396/24	Prepared by:

Test results refer to the documented test samples only. Test report shall not be reproduced except in full, without written approval of the laboratory. Sample has been provided by the customer and the results apply to the sample as received. Sample description in all cases in taken as described by the customer.



TEST REPORT

- 13 Test Request Control No& Date:** 1396/24, 22nd July 2024
- 14 Test Specification** Acceleration : 272g
Pule Duration : 3.7msec,
One shock per direction.
- 15 UUT Condition:** Good
- 16 Unique ID No. of Test Item:** DSRI/ETL/24/458/01
- 17 Environmental Conditions:** Temp: 34.8°C, Humidity: 50.5%RH
- 18 Test carried out at:** ET LAB
- 19 Deviation if any:** No Deviation
- 20 Equipment Used for test**
- 21 Nomenclature:** Shock Test Machine
Make/Model: NMSRI/TSTS-1010S
Calibration Validity: 10th September 2024
- 22 Test Setup:** The 65NB PN10 Globe Valve Fanged End, Sl. No: CI0968, manufactured by M/s Rappid Valves (India) Pvt. Ltd., been fixed to shock machine along with dedicated fixture in "As Fitted Condition".
- 23 Test Procedure:** Unit Under Test and accelerometer was mounted on the fixture as shown in figure and test was carried out as per the test method and standard for the required test specification.
- 24 Observation:** No structural deformity or damage was found during and after the test.
- 25 Conclusion:** The condition of UUT was found to be satisfactory upon visual inspection.

DSRI/F/64 Issue no: 02, Issue Date: 22-07-2024 Rev. no: 00, Rev Date: --	URL No: TC120602400001396F
Test Report No: DSRI/ETL/1396/24	Prepared by:

Test results refer to the documented test samples only. Test report shall not be reproduced except in full, without written approval of the laboratory. Sample has been provided by the customer and the results apply to the sample as received. Sample description in all cases in taken as described by the customer.



TEST REPORT

TEST FIGURE:



Figure-1: 65NB PN10 GLOBE VALVE FANGED END

DSRI/F/64 Issue no: 02, Issue Date: 22-07-2024 Rev. no: 00, Rev Date: --	URL No: TC120602400001396F
Test Report No: DSRI/ETL/1396/24	Prepared by:

Test results refer to the documented test samples only. Test report shall not be reproduced except in full, without written approval of the laboratory. Sample has been provided by the customer and the results apply to the sample as received. Sample description in all cases in taken as described by the customer.



TEST REPORT

Test Graphs:




Fig-2: 272g for 3.7msec

****END OF REPORT****

DSRI/F/64 Issue no: 02, Issue Date: 22-07-2024 Rev. no: 00, Rev Date: --	URL No: TC120602400001396F
Test Report No: DSRI/ETL/1396/24	Prepared by:

Test results refer to the documented test samples only. Test report shall not be reproduced except in full, without written approval of the laboratory. Sample has been provided by the customer and the results apply to the sample as received. Sample description in all cases in taken as described by the customer.



DEFENSE SYSTEMS RESEARCH INSTITUTE

Accredited by ISO / IEC 17025 : 2017 (NABL)

Lab Location : DSRI Labs Private Limited, Plot No 21, Road Number 4, IE, Nacharam, Road,
IDA Mallapur, Hyderabad - 500 076, Telangana, Website : <https://dsri.co.in> Email : info@dsri.co.in

JOINT INSPECTION REPORT FOR TORQUE TEST

Test conducted date: 19-07-2024

Report issued date: 19-07-2024

Report NO.: DSRI/Rappid/Globe Valve Flanged End/65NB/Torque Test-1

SI No.	Contents	Description
01	Client:	M/s. Rappid Valves (India) Private Limited
02	P.O No:	
03	Test Item:	65NB/PN10 Globe Valve Flanged End
04	S. No & Heat No.:	CIO968; 92-06
05	Material:	WCB
06	Drawing No.:	RV/GBV/FLG/001
07	Torque Wrench	
	Make/Model no.:	Griphold_GTW_50
	Range: Calib due date:	14-68 Nm; 06-10-2023 05-10-2024
08	Pressure Gauge used:	Pressure gauge (0-21bars)
09	Serial Number/ Id No.:	0-21bars_ Serial no: ECPL/M/P/11
		ID. No: NMSRI/WI-PG-070
10	Due Of Calibration:	Serial no: ECPL/M/P/11_09-09-2023
		ID. No: NMSRI/WI-PG-021_08-09-2024
11	Closing Torque:	46 N-m
12	Opening Torque:	50 N-m
13	Delay Torque Time:	4sec
14	Observation:	During the hydrostatic torque test at 10 bar pressure, the opening torque was measured at 50 Nm, the closing torque at 46 Nm, and the delay torque time is 4sec. These values indicate the valve's performance under pressure, ensuring its reliability and functionality in the system.

Test Engineer

B. Ravi Kumar
DSRI Labs Pvt. Ltd., (LAB)





DEFENSE SYSTEMS RESEARCH INSTITUTE

Accredited by ISO / IEC 17025 : 2017 (NABL)

Lab Location : DSRI Labs Private Limited, Plot No 21, Road Number 4, IE, Nacharam, Road,
IDA Mallapur, Hyderabad - 500 076, Telangana, Website : <https://dsri.co.in> Email : info@dsri.co.in

Test Figure:



Figure 1: 65NB PN10 TORQUE TEST SETUP